

BID ADDENDUM NO. 1

This bid addendum is for the following project:

SOUTH PINE STREET WATERLINE, CABY IMPROVEMENTS

Bids will be received by the City at the City Hall, 317 Broad Street, Nevada City, California, 95959, until 3:00 p.m. on December 1st, 2016. This addendum does not change the bid date or time.

Bid Addendum: The Trench Resurfacing detail has been revised to exclude slurry seal. No slurry seal will be required. See attached detail.

Refer to Detail NID SD1 for bedding and backfill.

DATED: _____

11/30/16

CITY OF NEVADA CITY



Bryan K. McAlister, P.E.


City Engineer

TRENCH RESURFACING
CITY OF NEVADA CITY

Bid Addendum #1
Slurry Seal not required.

CALTRANS TYPE II SLURRY SEAL. EXTEND 1' BEYOND HMA PATCH OR AS DIRECTED BY ENGINEER.

AC (P684-16)
3" HMA MIN. (2 LIFTS) OR MATCH EXISTING HMA ROAD SECTION WHICHEVER IS GREATER



8" CLASS 2 A.B. MIN. OR MATCH EXISTING ROAD STRUCTURAL SECTION DEPTH, WHICHEVER IS GREATER, 95% RELATIVE COMPACTION

APP #1
BACKFILL - SEE DETAIL MED SDI